

CERTIFICATE OF COMPLIANCE

Certificate Number 20141212-E194191
Report Reference E194191-20141024
Issue Date 2014-DECEMBER-12

Issued to: ABB SPA - ABB SACE DIVISION
VIA BAIONI CRISTOFORO 35
24123 BERGAMO BG ITALY

This is to certify that representative samples of LOW-VOLTAGE AC POWER CIRCUIT BREAKERS
See Addendum

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL1066, Low-Voltage AC and DC Power Circuit Breakers Used in Enclosures
NEMA C37.50, Switchgear Low Voltage AC Power Circuit Breakers Used in Enclosures - Test Procedures
IEEE C37.13, Low-Voltage AC Power Circuit Breakers Used in Enclosures
IEEE C37.13A, Low-Voltage AC Power Circuit Breakers Used in Enclosures - Amendment 1: Increase of Voltages to 1000 V AC and Below
IEEE C37.17, Trip Systems for Low-Voltage (1000 V and Below) AC and General Purpose (1500 V and Below) DC Power Circuit Breakers

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20141212-E194191
Report Reference E194191-20141024
Issue Date 2014-DECEMBER-12

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power circuit breakers –
1600A Frame – Types SACE E2.2B, E2.2N, E2.2S.
2000A Frame – Types SACE E2.2N, E2.2S, E2.2H, E2.2V.

Molded case circuit breakers frames -
1600A Frame – Types SACE E2.2B, E2.2N, E2.2S.
2000A Frame – Types SACE E2.2N, E2.2S, E2.2H, E2.2V.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

